CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 07/03/2019

Lab ID : **CP-2019-04-03-01**

Project Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

Agency : Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Date of Receipt : 02-03-2019

Customer ID : Pile Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of Test : 07/03/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pile Concrete	M20	28/02/2019	07/03/2019	150.64 X 149.51 X 149.46	22523	**8.011**	413.3	18.4	18.7
2	Pile Concrete	M20	28/02/2019	07/03/2019	151.44 X 150.13 X 149.68	22736	**8.894**	423.9	18.6	
3	Pile Concrete	M20	28/02/2019	07/03/2019	151.61 X 151.88 X 150.25	23027	**8.634**	437.4	19.0	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL PRO Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-04-03-01** **Date: 28/03/2019**

Project Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

Agency : Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Date of Receipt : 02-03-2019

Customer ID : Pile Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 28/03/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pile Concrete	M20	28/02/2019	28/03/2019	150.92 X 150.81 X 151.48	22760	**8.286**	543.0	23.9	23.5
2	Pile Concrete	M20	28/02/2019	28/03/2019	149.91 X 150.83 X 150.15	22611	**8.229**	517.5	22.9	
3	Pile Concrete	M20	28/02/2019	28/03/2019	149.92 X 151.99 X 151.14	22786	**8.730**	537.9	23.6	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 07/03/2019

Lab ID : **CP-2019-04-03-01**

Project Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

Agency : Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Date of Receipt : 02-03-2019

Customer ID : Pile Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 07/03/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pile Concrete	M20	28/02/2019	07/03/2019	150.58 X 149.24 X 150.79	22472	**8.011**	413.7	18.4	18.4
2	Pile Concrete	M20	28/02/2019	07/03/2019	150.54 X 151.50 X 151.49	22808	**8.894**	421.8	18.5	
3	Pile Concrete	M20	28/02/2019	07/03/2019	149.14 X 150.17 X 151.48	22397	**8.634**	409.0	18.3	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

****End of Report****

CIVIL PRO Sig..... Date..... BANGALORE

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-04-03-01** **Date: 28/03/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 02-03-2019

: Pile Concrete

: 150X150X150 mm

: M20 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 28/03/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Pile Concrete	M20	28/02/2019	28/03/2019	151.65 X 151.44 X 150.50	22965	**8.286**	529.2	23.0	23.0
Pile Concrete	M20	28/02/2019	28/03/2019	149.15 X 150.64 X 150.28	22469	**8.229**	498.8	22.2	
Pile Concrete	M20	28/02/2019	28/03/2019	151.39 X 149.56 X 151.49	22642	**8.730**	536.4	23.7	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 07/03/2019

: **CP-2019-04-03-01**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

: 02-03-2019

: Pile Concrete

: 150X150X150 mm

: M20 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 07/03/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Pile Concrete	M20	28/02/2019	07/03/2019	149.15 X 149.51 X 151.16	22300	**8.011**	413.5	18.5	18.3
Pile Concrete	M20	28/02/2019	07/03/2019	150.71 X 151.76 X 149.40	22872	**8.894**	416.6	18.2	
Pile Concrete	M20	28/02/2019	07/03/2019	150.15 X 150.50 X 151.51	22598	**8.634**	407.1	18.0	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL PRO BANGALORE Sig..... Date.....

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 28/03/2019

: **CP-2019-04-03-01**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 02-03-2019

: Pile Concrete

: 150X150X150 mm

: M20 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 28/03/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Pile Concrete	M20	28/02/2019	28/03/2019	151.73 X 151.50 X 150.69	22987	**8.286**	533.1	23.2	22.9
Pile Concrete	M20	28/02/2019	28/03/2019	151.76 X 151.21 X 151.08	22948	**8.229**	509.2	22.2	
Pile Concrete	M20	28/02/2019	28/03/2019	151.83 X 150.48 X 151.76	22847	**8.730**	530.9	23.2	

FOR CIVIL Pr

R KARTHIK RECHA
Authorized Signat
Quality Manag

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

****End of Report****

CIVIL Pro Sig..... Date..... BANGALORE

72924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-04-03-01** **Date: 07/03/2019**

Project Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

Agency : Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Date of Receipt : 02-03-2019

Customer ID : Pile Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of Test : 07/03/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pile Concrete	M20	28/02/2019	07/03/2019	150.79 X 151.68 X 149.07	22872	**8.011**	426.1	18.6	18.5
2	Pile Concrete	M20	28/02/2019	07/03/2019	149.51 X 149.31 X 149.18	22323	**8.894**	404.8	18.1	
3	Pile Concrete	M20	28/02/2019	07/03/2019	150.00 X 149.39 X 151.14	22409	**8.634**	417.3	18.6	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL PRO Sig..... Date..... BANGALORE

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 28/03/2019

Lab ID : CP-2019-04-03-01

Project Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

Agency : Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Date of Receipt : 02-03-2019

Customer ID : Pile Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of Test : 28/03/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
01	Pile Concrete	M20	28/02/2019	28/03/2019	151.94 X 150.49 X 151.04	22866	**8.286**	542.6	23.7	23.3
02	Pile Concrete	M20	28/02/2019	28/03/2019	149.08 X 149.51 X 151.14	22289	**8.229**	512.5	23.0	
03	Pile Concrete	M20	28/02/2019	28/03/2019	151.91 X 150.76 X 149.69	22903	**8.730**	531.0	23.2	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-04-03-01** **Date: 07/03/2019**

Project Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

Agency : Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Date of Receipt : 02-03-2019

Customer ID : Pile Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 07/03/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pile Concrete	M20	28/02/2019	07/03/2019	150.14 X 150.81 X 149.53	22643	**8.011**	411.4	18.2	18.4
2	Pile Concrete	M20	28/02/2019	07/03/2019	150.05 X 150.06 X 150.62	22517	**8.894**	421.2	18.7	
3	Pile Concrete	M20	28/02/2019	07/03/2019	149.50 X 150.20 X 150.27	22454	**8.634**	412.0	18.3	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

Page 1/1

****End of Report****

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : CP-2019-04-03-01 **Date: 28/03/2019**

Project Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

Agency : Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Date of Receipt : 02-03-2019

Customer ID : Pile Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/ Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of Test : 28/03/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pile Concrete	M20	28/02/2019	28/03/2019	149.40 X 149.23 X 151.43	22296	**8.286**	518.9	23.3	23.3
2	Pile Concrete	M20	28/02/2019	28/03/2019	151.29 X 150.84 X 150.82	22820	**8.229**	521.5	22.9	
3	Pile Concrete	M20	28/02/2019	28/03/2019	149.41 X 149.38 X 150.19	22320	**8.730**	528.8	23.7	

FOR CIVIL Pro.

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-04-03-01** **Date: 08/03/2019**

Project Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

Agency : Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Date of Receipt : 05-03-2019

Customer ID : Pile Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of Test : 08/03/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pile Concrete	M20	01/03/2019	08/03/2019	150.35 X 151.47 X 149.89	22773	**8.011**	432.4	19.0	18.7
2	Pile Concrete	M20	01/03/2019	08/03/2019	150.52 X 150.79 X 151.35	22697	**8.894**	428.2	18.9	
3	Pile Concrete	M20	01/03/2019	08/03/2019	151.86 X 151.13 X 149.74	22950	**8.634**	419.4	18.3	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

Page 1/1

****End of Report****

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-04-03-01** **Date: 29/03/2019**

Project Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

Agency : Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Date of Receipt : 05-03-2019

Customer ID : Pile Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 29/03/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pile Concrete	M20	01/03/2019	29/03/2019	151.14 X 151.41 X 149.13	22885	**8.286**	527.9	23.1	23.0
2	Pile Concrete	M20	01/03/2019	29/03/2019	149.93 X 149.31 X 150.92	22386	**8.229**	497.5	22.2	
3	Pile Concrete	M20	01/03/2019	29/03/2019	150.51 X 149.63 X 150.41	22521	**8.730**	537.2	23.9	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL PRO BANGALORE Sig..... Date.....

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-04-03-01** **Date: 08/03/2019**

Project Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

Agency : Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Date of Receipt : 05-03-2019

Customer ID : Pile Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 08/03/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pile Concrete	M20	01/03/2019	08/03/2019	149.04 X 151.14 X 151.41	22526	**8.011**	421.9	18.7	18.4
2	Pile Concrete	M20	01/03/2019	08/03/2019	150.48 X 151.97 X 149.76	22868	**8.894**	415.3	18.2	
3	Pile Concrete	M20	01/03/2019	08/03/2019	151.00 X 151.78 X 150.10	22919	**8.634**	416.4	18.2	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
BANGALORE

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-04-03-01** **Date: 29/03/2019**

Project Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

Agency : Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Date of Receipt : 05-03-2019

Customer ID : Pile Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of Test : 29/03/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pile Concrete	M20	01/03/2019	29/03/2019	151.09 X 149.66 X 149.53	22612	**8.286**	540.0	23.9	23.3
2	Pile Concrete	M20	01/03/2019	29/03/2019	149.94 X 149.71 X 150.41	22447	**8.229**	515.1	22.9	
3	Pile Concrete	M20	01/03/2019	29/03/2019	151.90 X 150.93 X 149.45	22926	**8.730**	532.3	23.2	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-04-03-01** **Date: 08/03/2019**

Project Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli Sub Division.

Agency : Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Customer's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Date of Receipt : 05-03-2019

Customer ID : Pile Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 08/03/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pile Concrete	M20	01/03/2019	08/03/2019	150.90 X 149.86 X 151.77	22614	**8.011**	422.3	18.7	18.6
2	Pile Concrete	M20	01/03/2019	08/03/2019	150.45 X 149.29 X 150.51	22461	**8.894**	422.2	18.8	
3	Pile Concrete	M20	01/03/2019	08/03/2019	151.62 X 151.00 X 151.94	22894	**8.634**	417.4	18.2	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

****End of Report****

CIVIL PRO BANGALORE Sig..... Date.....

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |